



Department of Public Works
Infrastructure Services Division

Ghassan Korban
Commissioner of Public Works

Preston D. Cole
Director of Operations

Jeffrey S. Polenske
City Engineer

August 14, 2015

Subject: Official Notice No. 121-1-2015

2nd and Plankinton Parking Structure
West Elevator Modernization
724 North 2nd Street
Milwaukee, Wisconsin

For which bid will be received on
Friday, August 21, 2015

Addendum No. 1

- A. In regard to our advertisement for the 2nd and Plankinton Parking Structure – West Elevator Modernization, 724 North 2nd Street, Milwaukee, Wisconsin this attached Addendum No. 1 is issued to modify the original documents and is hereby made part of the proposal.
- B. Each bidder shall read the entire addendum. Proposals shall include all items included in this Addendum No. 1.

Very truly yours,



Paul R. Fredrich, Facilities Operations Manager
Bridges and Buildings



Official Notice No. 121-1-2015

2nd and Plankinton Parking Structure
West Elevator Modernization
724 North 2nd Street
Milwaukee, Wisconsin

Addendum No. 1

IMMEDIATELY UPON RECEIPT OF THE ADDENDUM, PLEASE SIGN THIS RECEIPT AND
FAX BACK TO DPW-BRIDGES AND BUILDINGS SECTION AT (414) 286-5907 OR EMAIL
(dpitts@milwaukee.gov).

Company Name

Name

Date



**LERCH BATES***Building Insight***ADDENDUM # 1****Project 2nd & Plankinton**

To: All Bidders

Make the following changes to Section 14220 of the bid package:

Section	Description
1.04 B	Approved controllers shall be limited to Smartrise and GAL. MCE is no longer an approved controller for this project.
2.06 O	Delete Item, pit inspection platform is not required.
2.06 P	Delete item, pit inspection station is not required.
2.05 B	Gearless machine is an acceptable alternative. All other specifications must be met.
2.09	Clarification: Existing cab flooring is to remain.
3.03 F	Clarification: Any retained elevator equipment in the machine room shall be painted.

Please acknowledge receipt of this addendum on the bid form.